



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



**Annual Performance Report**

**Leamington Distribution System**

**Drinking Water System # 220004992**

**2022**

Prepared for the Municipality of Leamington

By the Ontario Clean Water Agency

**ANNUAL REPORT**

Drinking Water System Number:	220004992
Drinking Water System Name:	Leamington Distribution System (Union WSS)
Drinking Water System Owner:	The Municipality of Leamington
Drinking Water System Category:	Large Municipal Residential
Period being reported:	01-January-2022 to 31-December 2022

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking Water System serve more than 10,000 people? Yes [ X ] No [ ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Municipality of Leamington Office 111 Erie Street North, Leamington, ON N8H 2Z9</p> </div>	<p><b><u>Complete for all other Categories</u></b></p> <p>Number of Designated Facilities served:  <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to:  <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
---	--

**Note:** For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report

List all Drinking Water Systems (if any), which receive all their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all drinking water? Yes [ ] No [N/A]

Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking Water System**

A stand-alone distribution system serving a population of approx. 31,000 residents of the Municipality of Leamington.

**List all water treatment chemicals used over this reporting period**

N/A

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

None.

Provide details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

	Number of Samples	Range of E. Coli Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	Please see the Annual Report for the Union Water Supply System # 210000853				
Treated	Please see the Annual Report for the Union Water Supply System # 210000853				
Distribution	508	0-0	0-0	254	<10 - <30

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	Please see the Annual Report for the Union Water Supply System # 210000853		
Chlorine	676	0.54 – 1.56	mg/L
Fluoride (If the DWS provides fluoridation)	N/A		

**NOTE: For continuous monitors use 8760 as the number of samples**

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Nitrite (N)	04-Jan-2022	<0.1	mg/L	No
Nitrate (N)		0.6	mg/L	No
Ammonia N-Total		0.12	mg/L	No
Nitrite (N)	07-Apr-2022	<0.1	mg/L	No
Nitrate (N)		0.5	mg/L	No
Ammonia N-Total		<0.01	mg/L	No
Nitrite (N)	05-July-2022	< 0.1	mg/L	No
Nitrate (N)		0.3	mg/L	No
Ammonia N-Total		<0.01	mg/L	No
Nitrite (N)	03-Oct-2022	<0.1	mg/L	No
Nitrate (N)		0.1	mg/L	No
Ammonia N-Total		<0.01	mg/L	No

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	N/A			
Distribution	15	0.04 – 0.608	ug/L	None

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	Annual Average	22.75	ug/L	No
HAA (NOTE: show latest annual average)	Annual Average	9.125	ug/L	No

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards**

Parameter	Result Value	Unit of Measure	Date of Sample
None			