



Ontario Clean Water Agency
Agence Ontarienne Des Eaux



Annual Performance Report

Union Water Supply System

Drinking Water System # 210000853

2023

**Prepared for the Corporation of the Town of Kingsville, the Corporation of the
Town of Essex, the Municipality of Lakeshore & the Municipality of Leamington**

By the Ontario Clean Water Agency

ANNUAL REPORT

| | |
|--|---|
| Drinking Water System Number: | 210000853 |
| Drinking Water System Name: | Union Water Supply System |
| Drinking Water System Owner: | Union Water Supply System Joint Board of Management (Municipality of Leamington, Town of Kingsville, Town of Essex, Municipality of Lakeshore) |
| Drinking Water System Category: | Large Municipal Residential |
| Period being reported: | 01-January-2023 to 31-December-2023 |

| | |
|--|--|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Union Water Supply System P.O. Box 340, 1615 Union Ave., Ruthven, Ont. N0P 2G0 </div> | <p><u>Complete for all other Categories</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p> |
|--|--|

Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report

List all Drinking Water Systems (if any), which receive all their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|----------------------------|------------------------------|
| Municipality of Leamington | 220004992 |
| Town of Kingsville | 220003403 |
| Town of Essex | 220003680 |
| Municipality of Lakeshore | 260004995 |

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all drinking water?
 Yes [X] No []

Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking Water System

The Union Water Supply System (UWSS) includes one water treatment plant, the Ruthven Water Treatment Plant (RWTP) that is located in the hamlet of Ruthven in the Town of Kingsville, Ontario. The RWTP is a chemically assisted conventional filtration plant that draws water from Lake Erie.

The UWSS supplies potable water to the Town of Kingsville, Municipality of Leamington, a portion of the Town of Essex and a portion of the Municipality of Lakeshore with an estimated service population of 66,841.

The treatment process includes raw water pH control, chemically assisted up-flow clarification, chemically assisted Dissolved Air Flootation system, filtration with dual media filters, primary disinfection using Chlorine gas and secondary disinfection using Chlorine gas and Sodium Hypochlorite.

Seasonally, the RWTP uses sodium hypochlorite at its intakes to control Zebra Mussel formation.

There are also four water towers and a booster/storage station located on the Union Water Supply System.

List all water treatment chemicals used over this reporting period

- Zebra Mussel Control:**
- Sodium Hypochlorite – (Seasonal)
- Clarification Chemicals:**
- SternPAC 70 - Coagulant
 - NorFloc 122 (polymer) – Coagulant Aid
 - Powdered Activated Carbon – Taste and Odor Control
 - CO2 – PH adjustment
- Filtration:**
- Cat-Floc 8103 Plus (polymer) – Filter Aid (Seasonal)
-
- Disinfection:**
- Primary: Chlorine Gas
 - Secondary: Chlorine Gas and Sodium Hypochlorite

Were any significant expenses incurred to?

- Install required equipment

- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

| | Item Description | Expenditures to 2023 Year End |
|----|--|-------------------------------|
| | Capital Works and Major Maintenance | |
| 1 | Low Lift Pump Rehab | \$ 14,644 |
| 2 | Carbon System Pump Upgrades | \$ 29,718 |
| 3 | Highlift Pump #7 - Engineering and Design | \$ 44,322 |
| 4 | Surge Valves for High Lift Pumps #8 and #9 | \$ 45,079 |
| 5 | Air Compressor Upgrades | \$ 31,615 |
| 6 | Filter 2&4 Control Console Upgrades | \$ 117,024 |
| 7 | Electrical Upgrades - capacitors, etc. | \$ 24,676 |
| 8 | Communication System upgrades | \$ 23,044 |
| 9 | New Telephone System | \$ 24,100 |
| 10 | New VFDs and upgrades for Cottam Booster Pumps | \$ 124,573 |
| 11 | Albuna Water Tower Upgrades | \$ 61,665 |
| 12 | Meter Chamber Rehabilitation | \$ 48,728 |
| 13 | Water Quality Analyzers - | \$ 52,773 |
| 14 | Wastewater Pump - New backup pump | \$ 71,870 |
| 15 | Upgrade of UWSS 300mm Watermain-Victoria Avenue, Essex Centre | \$ 324,079 |
| 16 | Low Lift Travelling Screen #4 - New; Design and Engineering | \$ 97,843 |
| 17 | Clarifier #3 Improvements | \$ 21,740 |
| 18 | Kingsville Tower New Corrosion Control System | \$ 7,932 |
| 19 | DAF #1 Improvements | \$ 47,200 |
| 20 | Reservoir #3 Design and Engineering | \$ 318,183 |
| 21 | Maintenance Building Improvements - Bathroom and Sewage System | \$ 42,505 |
| 22 | Smart Hydrant Monitoring Network Improvements | \$ 61,050 |
| 23 | Quench Buggy Purchase | \$ 62,715 |
| 24 | New Vehicle | \$ 62,277 |
| 25 | OCWA Capital Expenditures | \$ 112,207 |
| | Total | \$ 1,871,562 |

Provide details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|--------------|------------------|-----------------|-------------------|------------------------|
| Aug 24, 2023 | Low Pressure | Pressure <20 psi | psi | BacT Samples | Aug 24, 2023 |

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

| | Number of Samples | Range of E. Coli Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|--------------|---|--|---|-----------------------|--------------------------------------|
| Raw | 52 | <2-40 | <2-690 | 0 | N/A |
| Treated | 52 | 0 – 0 | 0 – 0 | 52 | <10 - 40 |
| Distribution | Please See Individual Annual Reports for Distribution System Information: Leamington (220004992), Kingsville (220003403), Essex (220003680), and Lakeshore (260004995). | | | | |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) | Unit of Measure |
|-----------------|------------------------|----------------------------------|-----------------|
| Turbidity | 8760 | 0.01 – 1.18 | NTU |
| Chlorine - Free | 8760 | 0.82 - 2.84 | mg/L |

NOTE: For continuous monitors use 8760 as the number of samples

| Date of legal instrument issued | Parameter | Date Sampled | Result | Unit |
|---------------------------------|--------------------------|--------------|--------|------|
| Nov 26, 2021 | Total Chlorine residuals | Jan 09/2023 | 0.13 | mg/L |
| | Total Chlorine residuals | Feb 21/2023 | 0.12 | mg/L |
| | Total Chlorine residuals | Mar 13/2023 | 0.13 | mg/L |
| | Total Chlorine residuals | Apr 24/2023 | 0.12 | mg/L |
| | Total Chlorine residuals | May 08/2023 | 0.11 | mg/L |
| | Total Chlorine residuals | June 12/2023 | 0.11 | mg/L |
| | Total Chlorine residuals | July 26/2023 | 0.08 | mg/L |
| | Total Chlorine residuals | Aug 28/2023 | 0.14 | mg/L |
| | Total Chlorine residuals | Sept 11/2023 | 0.11 | mg/L |
| | Total Chlorine residuals | Oct 10/2023 | 0.13 | mg/L |
| | Total Chlorine residuals | Nov 20/2023 | 0.13 | mg/L |
| | Total Chlorine residuals | Dec 18/2023 | 0.13 | mg/L |
| | Annual Average | | 0.12 | mg/L |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| TREATED WATER | Sample Date (yyyy/mm/dd) | Sample Result | MAC | No. of Exceedances | |
|-----------------------|--------------------------|---------------|--------|--------------------|---------|
| | | | | MAC | 1/2 MAC |
| Antimony: Sb (ug/L) | 2023/01/10 | <MDL 0.6 | 6.0 | No | No |
| Arsenic: As (ug/L) | 2023/01/10 | 0.2 | 10.0 | No | No |
| Barium: Ba (ug/L) | 2023/01/10 | 18.2 | 1000.0 | No | No |
| Boron: B (ug/L) | 2023/01/10 | 16.0 | 5000.0 | No | No |
| Cadmium: Cd (ug/L) | 2023/01/10 | 0.008 | 5.0 | No | No |
| Chromium: Cr (ug/L) | 2023/01/10 | 0.26 | 50.0 | No | No |
| Mercury: Hg (ug/L) | 2023/01/10 | <MDL 0.01 | 1.0 | No | No |
| Selenium: Se (ug/L) | 2023/01/10 | 0.14 | 50.0 | No | No |
| Uranium: U (ug/L) | 2023/01/10 | 0.016 | 20.0 | No | No |
| Additional Inorganics | | | | | |
| Fluoride (mg/L) | 2023/01/10 | <MDL 0.06 | 1.5 | No | No |
| Nitrite (mg/L) | 2023/01/03 | 0.10 | 1.0 | No | No |
| Nitrite (mg/L) | 2023/04/03 | 0.05 | 1.0 | No | No |
| Nitrite (mg/L) | 2023/07/04 | 0.05 | 1.0 | No | No |
| Nitrite (mg/L) | 2023/10/03 | 0.05 | 1.0 | No | No |
| Nitrate (mg/L) | 2023/01/03 | 0.50 | 10.0 | No | No |
| Nitrate (mg/L) | 2023/04/03 | 0.80 | 10.0 | No | No |
| Nitrate (mg/L) | 2023/07/04 | 0.43 | 10.0 | No | No |
| Nitrate (mg/L) | 2023/10/03 | 0.05 | 10.0 | No | No |
| Sodium: Na (mg/L) | 2023/01/10 | 6.87 | 20* | No | No |

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20

mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| Location Type | Number of Samples | Range of Lead Results (min#) – (max #) | Number of Exceedances |
|---------------|---|--|-----------------------|
| Plumbing | Please See Individual Annual Reports for Distribution System Information: Leamington (220004992), Kingsville (220003403), Essex (220003680), and Lakeshore (260004995). | | |
| Distribution | Please See Individual Annual Reports for Distribution System Information: Leamington (220004992), Kingsville (220003403), Essex (220003680), and Lakeshore (260004995). | | |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| TREATED WATER | Sample Date (yyyy/mm/dd) | Sample Result | MAC | Number of Exceedances | |
|--|--------------------------|---------------|-------|-----------------------|---------|
| | | | | MAC | 1/2 MAC |
| Alachlor (ug/L) | 2023/01/10 | <MDL 0.02 | 5.0 | No | No |
| Atrazine + N-dealkylated metabolites (ug/L) | 2023/01/10 | <MDL 0.01 | 5.0 | No | No |
| Azinphos-methyl (ug/L) | 2023/01/10 | <MDL 0.05 | 20.0 | No | No |
| Benzene (ug/L) | 2023/01/10 | <MDL 0.32 | 1.0 | No | No |
| Benzo(a)pyrene (ug/L) | 2023/01/10 | <MDL 0.004 | 0.01 | No | No |
| Bromoxynil (ug/L) | 2023/01/10 | <MDL 0.33 | 5.0 | No | No |
| Carbaryl (ug/L) | 2023/01/10 | <MDL 0.05 | 90.0 | No | No |
| Carbofuran (ug/L) | 2023/01/10 | <MDL 0.01 | 90.0 | No | No |
| Carbon Tetrachloride (ug/L) | 2023/01/10 | <MDL 0.17 | 2.0 | No | No |
| Chlorpyrifos (ug/L) | 2023/01/10 | <MDL 0.02 | 90.0 | No | No |
| Diazinon (ug/L) | 2023/01/10 | <MDL 0.02 | 20.0 | No | No |
| Dicamba (ug/L) | 2023/01/10 | <MDL 0.2 | 120.0 | No | No |
| 1,2-Dichlorobenzene (ug/L) | 2023/01/10 | <MDL 0.41 | 200.0 | No | No |
| 1,4-Dichlorobenzene (ug/L) | 2023/01/10 | <MDL 0.36 | 5.0 | No | No |
| 1,2-Dichloroethane (ug/L) | 2023/01/10 | <MDL 0.35 | 5.0 | No | No |
| 1,1-Dichloroethylene (ug/L) | 2023/01/10 | <MDL 0.33 | 14.0 | No | No |
| Dichloromethane (Methylene Chloride) (ug/L) | 2023/01/10 | <MDL 0.35 | 50.0 | No | No |
| 2,4-Dichlorophenol (ug/L) | 2023/01/10 | <MDL 0.15 | 900.0 | No | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) | 2023/01/10 | <MDL 0.19 | 100.0 | No | No |
| Diclofop-methyl (ug/L) | 2023/01/10 | <MDL 0.4 | 9.0 | No | No |
| Dimethoate (ug/L) | 2023/01/10 | <MDL 0.06 | 20.0 | No | No |

| | | | | | |
|--|------------|-----------|-------|----|----|
| Diquat (ug/L) | 2023/01/10 | <MDL 1.0 | 70.0 | No | No |
| Diuron (ug/L) | 2023/01/10 | <MDL 0.03 | 150.0 | No | No |
| Glyphosate (ug/L) | 2023/01/10 | <MDL 1.0 | 280.0 | No | No |
| Malathion (ug/L) | 2023/01/10 | <MDL 0.02 | 190.0 | No | No |
| Metolachlor (ug/L) | 2023/01/10 | <MDL 0.01 | 50.0 | No | No |
| Metribuzin (ug/L) | 2023/01/10 | <MDL 0.02 | 80.0 | No | No |
| Monochlorobenzene (Chlorobenzene) (ug/L) | 2023/01/10 | <MDL 0.3 | 80.0 | No | No |
| Paraquat (ug/L) | 2023/01/10 | <MDL 1.0 | 10.0 | No | No |
| PCB (ug/L) | 2023/01/10 | <MDL 0.04 | 3.0 | No | No |
| Pentachlorophenol (ug/L) | 2023/01/10 | <MDL 0.15 | 60.0 | No | No |
| Phorate (ug/L) | 2023/01/10 | <MDL 0.01 | 2.0 | No | No |
| Picloram (ug/L) | 2023/01/10 | <MDL 1.0 | 190.0 | No | No |
| Prometryne (ug/L) | 2023/01/10 | <MDL 0.03 | 1.0 | No | No |
| Simazine (ug/L) | 2023/01/10 | <MDL 0.01 | 10.0 | No | No |
| Terbufos (ug/L) | 2023/01/10 | <MDL 0.01 | 1.0 | No | No |
| Tetrachloroethylene (ug/L) | 2023/01/10 | <MDL 0.35 | 10.0 | No | No |
| 2,3,4,6-Tetrachlorophenol (ug/L) | 2023/01/10 | <MDL 0.2 | 100.0 | No | No |
| Triallate (ug/L) | 2023/01/10 | <MDL 0.01 | 230.0 | No | No |
| Trichloroethylene (ug/L) | 2023/01/10 | <MDL 0.44 | 5.0 | No | No |
| 2,4,6-Trichlorophenol (ug/L) | 2023/01/10 | <MDL 0.25 | 5.0 | No | No |
| Trifluralin (ug/L) | 2023/01/10 | <MDL 0.02 | 45.0 | No | No |
| Vinyl Chloride (ug/L) | 2023/01/10 | <MDL 0.17 | 1.0 | No | No |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| N/A | N/A | N/A | N/A |

